CHL...CAL AND BACTERIOLOGICAL ANALYSIS

FORD ANALYTICAL LABORATORIES

DATE: 10/20/93 CERTIFICATE OF ANALYSIS

RIVERTON CITY CORP. P.O. BOX 429 RIVERTON, UTAH 84065

93-235050

SAMPLE:

DRINKING WATER SAMPLE COLLECTED 10-4-93, 8:45 A.M. BY

DUANE RECEIVED 10-4-93 FOR ANALYSIS.

STEFFENOFF WELL

59 1594 S 1127 E 670

		sults	Method Detection Limit	N4	35
Alkalinity CaCO3 mgl EPA310.1			. 50	N4 Sec	3
Antimony Sb mg/l EPA 204.2	(1)	.001	.0005		
Arsenic As mg/l EPA 200.9	(2)	.003 =	.0007		
Barium Ba mg/l EPA 200.7		.035 €	.0025		
Beryllium Be mg/l EPA 200.7	ND		.00030		
Bicarb. HCO3 mg/l SM4500-C02D	3	24;	.1		
Cadmium Cd mg/l EPA 200.7		ND -	.0010		
Calcium Ca mg/l EPA 200.7	1	35 🗸	. 100		
Carbon Dioxide CO2 mgl SM4500-		10.4	.01		
Carbonate CO3 mg1 SM4500-CO2D		.8,	.10		
Carbonate Solids mg/l	160		.30		
Chloride Cl mg/l EPA 300	1	68 ^{per}	. 50		
Chromium Cr mg/l EPA 200.7		.004	.0025		
Cond. umhos/cm EPA 120.1	130	20 ‡	.1		
Copper Cu mg/l EPA 220.1	1	ND .	.007		
Cyanide Cn tot.mg/l EPA 335.2	1	ND	.050		

(1) MATRIX SPIKE BIASED HIGH.

All reports are submitted as the confidential property of clients. Authorization for publication of our reports, conclusions, or, extracts from or regarding them, is reserved pending our written approval as a mutual protection to clients, the public and ourselves.

FORD ANALYTICAL LABORATORIES

PAGE: 2

CERTIFICATE OF ANALYSIS

93-235050

		Method Detection Limit
Fluoride, F mg/l EPA 300	<.1	.05
Hardness,CaC03 mg/l EPA 242	487	1.0
Hydrox. as OH mg1 SM4500-C02D	ND /	.10
Iron Fe mg/l EPA 236.1	.025	.010
Lead Pb mg/l EPA 239.2	.004 🗸	.0007
Magnesium Mg mg/l EPA 200.7	36.7	.100
Manganese Mn mg/l EPA 243.1	ND -	.0050
Mercury, Hg mg/l EPA 245.1	ND 🛩	.0002
Nickel Ni mg/l EPA 249.2	ND 🛩	.001
Nitrate NO3-N mg/l EPA 300	3.04 -	.01
Nitrite NO2-N mg/l EPA 354	.02 v	.01
Phosphorus Tot P mg/l EPA 365.	ND 🗸	.10
Potassium K mg/l EPA 200.7	3.57✓	.16
Selenium Se mg/l EPA 270.2	(2) .001	.0005
Silver Ag mg/l EPA 272.1	ND w	.0012
Sodium Na mg/l EPA 200.7	100 /	. 500
Sulfate SO4 mg/l EPA 300	200 🖟	.5
Susp. Solids mg/l EPA 160.2	2	1.0
Thallium Tl mg/l EPA 279.2	ND	.0005
Tot.Dis.Solids mg/l EPA 160.1	856√	10.0
Turbidity NTU EPA 180.1	ND /	.50

(2) ESTIMATED QUANTITY, ELEMENT DETECTED IN LAB BLANK.

All reports are submitted as the confidential property of clients. Authorization for publication of our reports, conclusions, or, extracts from or regarding them, is reserved pending our written approval as a mutual protection to clients, the public and ourselves.

FORD ANALYTICAL LABORATORIES

IICAL AND BACTERIOLOGICAL ANALYSIS

PAGE: 3 **CERTIFICATE OF ANALYSIS**

93-235050

Results

Method Detection

.0045

Limit

Zinc Zn mg/l EPA 289.1

.007 t

pH Units EPA 150.1

7.3

ND - INDICATES NONE DETECTED *

- INDICATES THE SMALLEST QUANTITY DETECTABLE DUE TO REQUIRED DILUTION **

All reports are submitted as the confidential property of clients. Authorization for publication of our reports, conclusions, or, extracts from or regarding them, is reserved pending our written approval as a mutual protection to clients, the public and ourselves.